


**Copy of the certificate regarding Water, Health & Sanitation
issued by the Sanitary Superintendent Officer, Ahmedabad
Municipal Corporation**



SATYAMEVA JAYATE INTERNATIONAL SCHOOL

Principal,
Satyameva Jayate International School
Ahmedabad



TRUSTEE

Copy of the Water Examination Report



AHMEDABAD MUNICIPAL CORPORATION

MAHANAGAR SEVA SADAN

CENTRAL LABORATORY

(An ISO 9001: 2015 Accredited Laboratory)



Lic No QAC/R01/4659

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631103, 25630438.

April 07, 2025.

To,
The Principal,
Satyamev Jayate International School,
E 2/41, Sterling City
Bopal, Ahmedabad

Dear Sir,


We have analyzed your water samples collected on Dt. 03-04-2025 for the following Chemical and Bacteriological parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
A. Organoleptic and Physical Parameters				
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	8.4
3	Turbidity, NTU, Max	1	5	0.10
4	Total dissolved solids, mg/l, Max	500	2000	296
B. General Parameters				
1	Total hardness (as CaCO ₃), mg/l, Max	200	600	150
2	Calcium (as Ca), mg/l, Max	75	200	40
3	Magnesium (as Mg), mg/l, Max	30	100	12.2
4	Chloride (as Cl), mg/l, Max	250	1000	55
5	Sulphate (as SO ₄) mg/l, Max	200	400	12.2
6	Total alkalinity (as CaCO ₃), mg/l, Max	200	600	160
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil
C. Bacteriological Quality of Drinking Water				
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable

Remarks:

1. The Central Laboratory, AMC, has collected the samples.
2. The result contained in this report relate only to the sample material tested.
3. The report is not being reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.


Dr. Hiren C. Mandalia
Scientist In-Charge


SATYAMEVA JAYATE INTERNATIONAL SCHOOL

Principal,
Satyameva Jayate International School
Ahmedabad


TRUSTEE